Project	
•	
Catalogue n°	



AUKÏO GEN 2 - KIOS LED LINEAR SURFACE **CONTINUOUS RUN FROM 2FT TO 100FT**

OPTIONAL EMERGENCY REMOTE

The Aukio GEN 2 is a robust LED luminaire that offers a high-power source that is ideal for work and commercial spaces. The Aukïo series allows you to achieve a consistently simple and elegant look throughout a space, without compromising the efficiency.



OVERVIEW			
LIGHT SOURCE	LED	COLOR TEMPERATURE (K)	3 000, 3 500, 4 000, 5 000
WATTAGE ¹ (W)	13.6 - 36.5	CRI	80+ AND 90+
LUMENS (LM)	375 - 1 000	WEIGHT (LBS)	2.863
LM/W	103.43 - 114.34		





MERGENCY LIGHTING



CANADIAN



LED







DAMP LOCATION



ICES 005





² 5 year warranty for the BRIDGE module.

Data is based upon tests performed in a controlled environment. Actual performance can vary depending on operating conditions. All products are subject to change or may be discontinued any time without notice.



KIOS • REV. 2023-10-18 т 514 227-1288 TF 1866 348-2374 aimlite.com





FEATURES & SPECIFICATIONS

CONSTRUCTION

Housing

The body is made of extruded aluminum.

Lens

Opal acrylic frosted lens diffuses light evenly.

Finishes

Matte silver, semi-gloss white, matte black finish standard and other special color option available upon request.

INSTALLATION

Only surface ceiling.

SPECIFICATIONS

Driver Options

DIM1 - 0-10 V dimming standard DIM2 - Line voltage driver 120V DALI1 - Digital addressable lighting interface driver (Not available in 347V)

Ambient temperature: -20°C ~ +50°C

OPTIONAL EMERGENCY LIGHTING

BRIDGE Normally ON Emergency Remote LED linear surface

- Consuming 11 W, 12 24 V DC
- 200 mA constant current
- Delivers 997 1 068 lumens in emergency mode
- Ease of maintenance when used with AimLite emergency lighting battery units complete with auto test function
- Complements AimLite's normally ON LED linear surface family
- Patent pending

Please view the BRIDGE specification section for more details on this technology

EMERGENCY LIGHTING COMPLIANCES

- CSA certified as a C22.2 C141-15 emergency lighting luminaire
- Meets ICES-005 requirements

GENERAL LIGHTING COMPLIANCES

- cCSAus
- · ICES-005 for Class A products
- CSA Certified to C22.2#141-15 (When used with BRIDGE option)
- · Suitable for damp locations

APPROVED DIMMER LIST			
LUTRON	VISIT WWW.LUTRON.COM/ADVANCE FOR A LIST OF DIMMERS (MARK VII) THAT WILL WORK WITH THIS DRIVER		
LEVITON	ILLUMATECH IP7 SERIES		
PHILIPS	SUNRISE - SR1200ZTUNV		


TM21 TABLE	
TIME (T) AT WHICH TO ESTIMATE LUMEN MAINTENANCE (HOURS)	50 000
LUMEN MAINTENANCE AT TIME (T) (%)	88.47 %
CALCULATED L70 (HOURS)	150 000
REPORTED L70 (HOURS)	>90 000

Note: Lumens are based on 3 000 K color temperature.





ORDERING GUIDE



¹ For lengths longer than 21', please consult factory.

When in emergency mode, luminaire only consumes 11 W.

For emergency lighting spacing, please see page 5.

BRIDGE TECHNICAL SPECIFICATIONS TABLE

		3 000 K	3 500 K	4 000 K	5 000 K
LUMEN	BRIDGE WATTS	BRIDGE	BRIDGE	BRIDGE	BRIDGE
PACKAGE	WAITE	LUMEN	LUMEN	LUMEN	LUMEN
	(W/FT)	OUTPUT	OUTPUT	OUTPUT	OUTPUT
		[LM/FT]	(LM/FT)	[LM/FT]	[LM/FT]
A1	4	257.81	257.81	260.39	260.39
A2	5	261.83	261.83	264.46	267.08
A3	7	250.39	250.39	252.89	255.40
A4	9	249.26	249.26	251.75	254.24

^{*} Data based on 80CRI fixtures .

DIMENSIONS



FIXTURE LENGHT

IMPERIAL (FT)	METRIC (MM)
2' 1 1/8"	638
3' 7/8"	936
4' 5/8"	1 234
5' 3/8"	1 533
6' 1/8"	1 831
6' 11 7/8"	2 130
7' 11 5/8"	2 428
8' 11 11/16"	2 737
9' 11 1/2"	3 035
10' 11 3/16"	3 334
11' 11"	3 632
12' 10 15/16"	3 936
13' 10 11/16"	4 234
14' 10 7/16"	4 532
15' 10 3/16"	4 831
16' 10 1/8"	5 134
17' 9 15/16"	5 433
18' 9 5/8"	5 731
19' 9 7/16"	6 030
20' 9 5/16"	6 333
	2' 1 1/8" 3' 7/8" 4' 5/8" 5' 3/8" 6' 1/8" 6' 11 7/8" 7' 11 5/8" 8' 11 11/16" 9' 11 1/2" 10' 11 3/16" 11' 11" 12' 10 15/16" 13' 10 11/16" 14' 10 7/16" 15' 10 3/16" 16' 10 1/8" 17' 9 15/16" 18' 9 5/8"

10ver 21 feet, consult factory.

 $^{^{2}}$ EL1 BRIDGE Normally On option for lengths 2' to 8', only up to 4' lighted up in emergency mode.

³ EL2 BRIDGE Normally On option for lengths 5' to 8', full length lighted up in emergency mode.

⁴ EL BRIDGE Normally On emergency option for lengths greater than 8' consult factory.

⁵ Please check BRIDGE Technical Specifications Table for delivery lumens with /EL option.

⁶ For custom color, please consult factory.




BRIDGE NORMALLY ON EMERGENCY REMOTE LUMINAIRE

This luminaire can be used with an emergency backup powered by either a 12 V or 24 V DC AimLite battery unit, complete with or without auto test.

NORMAL MODE



EMERGENCY MODE



TYPICAL SPECIFICATION

Supply and install AimLite BRIDGE ____ft, LED linear surface, Model number: _ remote normally ON emergency luminaire, CSA C22.2 141-15 certified and meet the requirements prescribed by ICES-005. Normally ON when AC is present and when connected to an AimLite battery unit complete with or without auto test, the luminaire shall act as an emergency lighting remote and consume 11 W of DC power in _____ V producing 997 - 1068 lumens in emergency mode.

The remote normally ON emergency luminaire shall be powered by an AimLite emergency lighting battery unit as described herein and shown on the drawings. The AimLite auto diagnostic micro-controller board shall supply the rated load for a minimum of a 1/2 hour to 87.5% of the rated battery voltage. The unit shall be rated 120 V, 277 V or 347 V, 60 Hz and be CSA listed. The unit shall have an output of: __V and __W.

The charge voltage factory set to ± 1% tolerance. High efficiency, rapid recovery, precision control charging system shall be employed to promote long battery life and reduce the potential for grid corrosion. The charger shall provide a continuous high charge to recharge the battery, when the battery is at full capacity, the charger will shut-off. Periodically the charger shall provide a pulse of energy to keep the battery topped off. The pulse charger shall be precisely regulated and shall charge the battery in relation to its temperature, state or charge and input voltage fluctuations. The charger shall be current limited, temperature compensated, short-circuit proof and reverse polarity protected. The unit shall be furnished with an electronic lockout circuit, which will connect the battery when the AC circuit is activated, and an electronic brownout circuit, which will activate the emergency lights when utility power dips below 75% of nominal voltage. A low voltage battery protection circuit shall be provided and will disconnect the load when the battery reaches the end of discharge. The automated testing performed by the AimLite auto test system has been designed to comply with all of the requirements of the

National Fire Code, Every month, a 5 minute discharge and diagnostic test checks the operational status of the unit. Every 12 months, this test is extended to the full 30 minute, code required duration. This ensures that the battery charger is recharging the battery in accordance with code requirements.

The unit shall be AimLite model: EBST_

Data is based upon tests performed in a controlled environment. Actual performance can vary depending on operating conditions. All products are subject to change or may be discontinued any time without notice.







BRIDGE NORMALLY ON EMERGENCY REMOTE LUMINAIRE







LEGEND



Emergency mode	Spacing
KIOS	Average spacing for 1 out of every 4 luminaires, normally ON in the path of egress, when at 8, 10, or 12 foot mounting heights.

Data is based upon tests performed in a controlled environment. Actual performance can vary depending on operating conditions. All products are subject to change or may be discontinued any time without notice.






GENERAL PHOTOMETRIC DATA¹

KIOS-04LA180-XX-40K • 1 473.8 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY


ZONE	LUMENS	% FIXTURE
0-30	409.5	27.8
0-40	665.9	45.2
0-60	1 164.1	79
60-90	309.7	21
70-100	131.2	8.9
90-120	0	0
0-90	1 473.8	100
90-180	0	0
0-180	1 473.8	100

ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM	WIDTH
2.0'	133.8		5.5'	5.7'
4.0'	33.5		10.9'	11.3'
6.0'	14.9		16.4'	17.0'
8.0'	8.4		21.9'	22.7'
10.0'	5.4		27.4'	28.4'
■ Vei	■ Vert. Spread: 107.7° ■ Hor. Spread: 109.6°			

KIOS-04LA280-XX-40K • 2 046.9 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY


ZONE	LUMENS	% FIXTURE
0-30	568.7	27.8
0-40	924.8	45.2
0-60	1 616.7	79
60-90	430.1	21
70-100	182.2	8.9
90-120	0	0
0-90	2 046.9	100
90-180	0	0
0-180	2 046.9	100

ILLUMINANCE AT A DISTANCE

CENT	ER BEAM FC		BEAM	WIDTH
2.0'	185.8		5.5'	5.7'
4.0'	46.5		10.9'	11.3'
6.0'	20.6		16.4'	17.0'
8.0'	11.6		21.9'	22.7'
10.0'	7.4		27.4'	28.4'
■ Vert. Spread: 107.7° ■ Hor. Spread: 109.6°				

KIOS-04LA380-XX-40K • 3 049.9 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY

ZONE	LUMENS	% FIXTURE
0-30	874	27.8
0-40	1 378.0	45.2
0-60	2 409.0	79
60-90	640.9	21
70-100	271.5	8.9
90-120	0	0
0-90	3 049.9	100
90-180	0	0
0-180	3 049.9	100

ILLUMINANCE AT A DISTANCE

CENTER BEAM FC BEAM WIDT						
2.0'	276.9		5.5'	5.7'		
4.0'	69.2		10.9'	11.3'		
6.0'	30.8		16.4'	17.0'		
8.0'	17.3		21.9'	22.7'		
10.0'	11.1		27.4'	28.4'		
■ Vert. Spread: 107.7° ■ Hor. Spread: 109.6°						

¹ Complete IES files available on our website.






GENERAL PHOTOMETRIC DATA¹

KIOS-04LA480-XX-40K • 4 073.3 LM

POLAR CANDELA DISTRIBUTION



ZONAL LUMEN SUMMARY

ZONE	LUMENG	0/ FIVTURE
ZONE	LUMENS	% FIXTURE
0-30	1 131.7	27.8
0-40	1840.4	45.2
0-60	3 217.3	79
60-90	856.0	21
70-100	362.7	8.9
90-120	0	0
0-90	4 073.3	100
90-180	0	0
0-180	4 073.3	100

ILLUMINANCE AT A DISTANCE

CENTER BEAM FC			BEAM WIDTH		
2.0'	369.8		5.5'	5.7'	
4.0'	92.5		10.9'	11.3'	
6.0'	41.1		16.4'	17.0'	
8.0'	23.1		21.9'	22.7'	
10.0'	14.8		27.4'	28.4'	
■ Vert. Spread: 107.7° ■ Hor. Spread: 109.6°					



¹ Complete IES files available on our website.