


Les produits d'éclairage

AimLite


Lighting Products

Filename: R12R-1-LA2-80-40K-S**Manufacturer:** Aimlite lighting**Luminaire:** R12R-L**Luminaire Cat:** R12R-1-L-A2-80-(A-H)-(B-W)-(B-S-W)-(B-S-W)-40K-S**Lamp:** (1) COB VERO18-(BXRC-30G4000-C-73-SE) c/w Universal Driver
D15CC55UNVTW-LS @ 120.00V**Distribution:** Direct Type - Downlight**Lamp Output:** Total luminaire Lumens: 3445.3**Max Candela:** 13,612.4 at Horizontal: 0°, Vertical: 1°**Input Wattage:** 33**Luminous Opening:** Circular (Dia: 2.75")**Test:** S1702205-R1 config from**Test Lab:** Spectra Lux Industries Inc.**Photometry :** Type C**CIE Class:** Direct**Cutoff Class:** Full Cutoff**Nema Type:** 4 X 4**Zonal Lumen Summary**

Zone	Lumens	% Luminaire
0-30	2,836.6	82.3%
0-40	3,370.0	97.8%
0-60	3,445.3	100%
60-90	0	0%
70-100	0	0%
90-120	0	0%
0-90	3,445.3	100%
90-180	0	0%
0-180	3,445.3	100%

Lumens Per Zone

Zone	Lumens	% Total	Zone	Lumens	% Total
0-10	1,092.9	31.7%	90-100	0	0%
10-20	1,099.2	31.9%	100-110	0	0%
20-30	644.5	18.7%	110-120	0	0%
30-40	533.5	15.5%	120-130	0	0%
40-50	75.2	2.2%	130-140	0	0%
50-60	0	0.0%	140-150	0	0%
60-70	0	0.0%	150-160	0	0%
70-80	0	0.0%	160-170	0	0%
80-90	0	0.0%	170-180	0	0%



Coefficients Of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance: 20%

RCC %:	80				70				50				30				10				0
RW %:	70	50	30	0	70	50	30	0	50	30	20	10	50	30	20	10	50	30	20	10	0
RCR: 0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.00	1.11	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.02	1.02	1.00
1	1.15	1.12	1.10	1.08	1.12	1.10	1.08	.96	1.06	1.05	1.03	1.02	1.01	1.00	.99	.98	.97	.96	.94	.93	.91
2	1.10	1.06	1.03	1.00	1.08	1.05	1.02	.92	1.01	.99	.97	.95	.94	.93	.92	.90	.89	.88	.86	.84	.82
3	1.06	1.01	.97	.94	1.04	1.00	.96	.88	.97	.94	.91	.89	.88	.86	.84	.82	.81	.80	.78	.76	.74
4	1.02	.96	.92	.88	1.01	.95	.91	.84	.93	.90	.87	.85	.84	.82	.80	.78	.76	.75	.73	.71	.69
5	.98	.92	.87	.84	.97	.91	.87	.81	.89	.86	.83	.81	.80	.78	.76	.75	.73	.72	.70	.68	.66
6	.95	.88	.83	.80	.94	.87	.83	.78	.86	.82	.79	.77	.76	.74	.73	.71	.70	.68	.66	.64	.62
7	.92	.84	.80	.76	.91	.84	.79	.75	.83	.79	.76	.74	.73	.71	.70	.68	.66	.64	.62	.60	.58
8	.89	.81	.76	.73	.88	.81	.76	.72	.80	.76	.73	.71	.70	.68	.66	.64	.62	.60	.58	.56	.54
9	.86	.78	.74	.70	.85	.78	.73	.70	.77	.73	.70	.68	.66	.64	.62	.60	.58	.56	.54	.52	.50
10	.83	.75	.71	.68	.82	.75	.71	.67	.74	.70	.68	.66	.64	.62	.60	.58	.56	.54	.52	.50	.48

Luminaire Report Summary

IESNA:LM-63-2002
 [ISSUE DATE] 20 February 2017
 [TEST LAB] Spectra Lux Industries Inc.
 [TEST] S1702205-R1 config from
 [MANUFACTURER] Aimlite lighting
 [LUMINAIRE] R12R-1-L-A2-80-(A-H)-(B-W)-(B-S-W)-(B-S-W)-40K-S
 [LUMINAIRE] R12R-L
 [LAMP] (1) COB VERO18-(BXRC-30G4000-C-73-SE) c/w Universal Driver D15CC55UNVTW-LS
 @ 120.00V
 [_BURNING] Vertical Base Up (3,448 Luminaire Lumens)
 [_REFLECTOR] Specular Spun Aluminum (Spot)
 [_LENS] None
 [_HOUSING] Fabricated Metal Sheet
 [DISTRIBUTION] Direct Type - Downlight

 FILE: CREATED USING ABSOLUTE PHOTOMETRY
 FILE: CANDELA MULTIPLIER: 0.76
 FILE: VERTICAL ANGLES: 67, HORIZONTAL ANGLES: 1
 FILE: COORDINATE SYSTEM: TYPE C
 FILE: UNIT OF MEASURE: STANDARD
 FILE: BALLAST FACTOR: 1

Photometrics Pro 1.3.29 copyright 2003-2018 by jSolutions, Inc.
 Reported data calculated from manufacturer's data file, based on IES recommended methods.