


Les produits d'éclairage

AimLite


Lighting Products

Filename: R12R-1-LA3-80-30K-S**Manufacturer:** Aimlite lighting**Luminaire:** R12R-L**Luminaire Cat:** R12R-1-L-A3-80-(A-H)-(B-W)-(B-S-W)-(B-S-W)-30K-S**Lamp:** (1) COB VERO18-(BXRC-30G4000-C-73-SE) c/w Universal Driver
D15CC55UNVTW-LS @ 120.00V**Distribution:** Direct Type - Downlight**Lamp Output:** Total luminaire Lumens: 4578.6**Max Candela:** 18,090.1 at Horizontal: 0°, Vertical: 1°**Input Wattage:** 45**Luminous Opening:** Circular (Dia: 2.75")**Test:** S1702205-R1 config from**Test Lab:** Spectra Lux Industries Inc.**Photometry :** Type C**CIE Class:** Direct**Cutoff Class:** Full Cutoff**Nema Type:** 4 X 4**Zonal Lumen Summary**

Zone	Lumens	% Luminaire
0-30	3,769.6	82.3%
0-40	4,478.6	97.8%
0-60	4,578.6	100%
60-90	0	0%
70-100	0	0%
90-120	0	0%
0-90	4,578.6	100%
90-180	0	0%
0-180	4,578.6	100%

Lumens Per Zone

Zone	Lumens	% Total	Zone	Lumens	% Total
0-10	1,452.4	31.7%	90-100	0	0%
10-20	1,460.8	31.9%	100-110	0	0%
20-30	856.5	18.7%	110-120	0	0%
30-40	709.0	15.5%	120-130	0	0%
40-50	100.0	2.2%	130-140	0	0%
50-60	0	0.0%	140-150	0	0%
60-70	0	0.0%	150-160	0	0%
70-80	0	0.0%	160-170	0	0%
80-90	0	0.0%	170-180	0	0%



Coefficients Of Utilization - Zonal Cavity Method

Effective Floor Cavity Reflectance: 20%

RCC %:	80				70				50				30				10				0
RW %:	70	50	30	0	70	50	30	0	50	30	20		50	30	20		50	30	20		0
RCR: 0	1.19	1.19	1.19	1.19	1.16	1.16	1.16	1.00	1.11	1.11	1.11		1.06	1.06	1.06		1.02	1.02	1.02		1.00
1	1.15	1.12	1.10	1.08	1.12	1.10	1.08	.96	1.06	1.05	1.03		1.02	1.01	1.00		.99	.98	.97		.96
2	1.10	1.06	1.03	1.00	1.08	1.05	1.02	.92	1.01	.99	.97		.99	.97	.95		.96	.94	.93		.91
3	1.06	1.01	.97	.94	1.04	1.00	.96	.88	.97	.94	.91		.95	.92	.90		.93	.90	.89		.87
4	1.02	.96	.92	.88	1.01	.95	.91	.84	.93	.90	.87		.91	.88	.86		.89	.87	.85		.84
5	.98	.92	.87	.84	.97	.91	.87	.81	.89	.86	.83		.88	.84	.82		.86	.83	.81		.80
6	.95	.88	.83	.80	.94	.87	.83	.78	.86	.82	.79		.84	.81	.78		.83	.80	.78		.77
7	.92	.84	.80	.76	.91	.84	.79	.75	.83	.79	.76		.81	.78	.75		.80	.77	.75		.74
8	.89	.81	.76	.73	.88	.81	.76	.72	.80	.76	.73		.79	.75	.72		.78	.75	.72		.71
9	.86	.78	.74	.70	.85	.78	.73	.70	.77	.73	.70		.76	.72	.70		.75	.72	.70		.69
10	.83	.75	.71	.68	.82	.75	.71	.67	.74	.70	.68		.74	.70	.67		.73	.70	.67		.66

Luminaire Report Summary

IESNA:LM-63-2002
 [ISSUE DATE] 20 February 2017
 [TEST LAB] Spectra Lux Industries Inc.
 [TEST] S1702205-R1 config from
 [MANUFAC] Aimlite lighting
 [LUMCAT] R12R-1-L-A3-80-(A-H)-(B-W)-(B-S-W)-(B-S-W)-30K-S
 [LUMINAIRE] R12R-L
 [LAMP] (1) COB VERO18-(BXRC-30G4000-C-73-SE) c/w Universal Driver D15CC55UNVTW-LS
 @ 120.00V
 [_BURNING] Vertical Base Up (4,583 Luminaire Lumens)
 [_REFLECTOR] Specular Spun Aluminum (Spot)
 [_LENS] None
 [_HOUSING] Fabricated Metal Sheet
 [DISTRIBUTION] Direct Type - Downlight

FILE: CREATED USING ABSOLUTE PHOTOMETRY
 FILE: CANDELA MULTIPLIER: 1.01
 FILE: VERTICAL ANGLES: 67, HORIZONTAL ANGLES: 1
 FILE: COORDINATE SYSTEM: TYPE C
 FILE: UNIT OF MEASURE: STANDARD
 FILE: BALLAST FACTOR: 1

Photometrics Pro 1.3.29 copyright 2003-2018 by jSolutions, Inc.
 Reported data calculated from manufacturer's data file, based on IES recommended methods.